

RESILIENT SEATED GATE VALVE SIZES 2"-24" AWWA C509 & C515

INSTALLATION & OPERATION MANUAL

TABLE OF CONTENTS

PAGE

Introduction	2
Receiving & Storage	.2
Installation	. 2
Operation	. 2
Maintenance	2
Stem Seal Procedure	. 3
Troubleshooting	5
Parts & Service	. 5
Drawings	. 6



1201 Vanderbilt Road | Birmingham, AL 35234 866.924.8674 • mcwanepi.com sales@mcwanepi.com MPIK-4011-2 04/23

INTRODUCTION

Resilient Seated Gate Valves (RSGV) were introduced to the waterworks industry in the 1980's and became a dominant preference for use in distribution systems. This manual will provide you with the information needed to properly install, operate, and maintain the valve and to provide long service life. RSGVs are available as a Full Wall (FW) or Reduced Wall (RW) resilient seated valve and comply with AWWA C509 or C515 standards

The RSGV contains a wedge fully encapsulated with EPDM rubber that is permanently bonded to the wedge and meets ASTM D249. The RSGV body, bonnet, and stuffing plate are coated with fusion bonded epoxy (FBE) and applied in accordance with AWWA C550 and are ANSI / NSF 61/372 certified.

Optional configurations also include a Non-Rising Stem (NRS) or Outside Screw & Yoke (OS&Y). RSGVs also can be ordered with a Spur or Bevel Gear.

RECEIVING & STORAGE

Inspect valves upon receipt to ensure correct material, quantity, and any optional equipment has been received. Also inspect all received equipment for any damage which may have occurred during shipment. Contact the McWane Plant & Industrial team to report any issues with materials received. RSGV requires no routine maintenance except that the valve must be operated at least once a year to prevent stem binding due to rust and encrustation.

Unload all valves safely to protect both the materials and workers. Do not allow lifting lugs, slings, or chains to encounter the valve wedge seating surface areas. Store valves indoors with the valve in the fully closed position to prevent damage to the seating surface by foreign material. If outdoor storage is required valves need to be protected from weather and foreign materials. In colder climates where freezing may occur, remove any water from the valve interior and close valve before storage to prevent cracking of the valve casting and deterioration of the resilient seated EPDM.

INSTALLATION

WARNING: Installation of valves should be performed by experienced installers. Valves should never be used as structural supports and movement into place. Valves are heavy and may include accessories or bolt on pieces which should be handled with caution.

NOTE: BEFORE INSTALLING THE VALVE:

- 1. Wipe away any dirt and grit from the inside of the valve
- **2.** Flush the line completely.
- **3.** Check the operation of the valve full open to full closed when installing the valve.
- 4. Cover the valve with burlap or similar material while backfilling to protect the coating after installing the valve.
- **5.** Open the valve about five turns and allow the flow an opportunity to flush any trash and debris from the line.

It is recommended that valves be installed into piping system in accordance with AWWA M-11 to prevent any undue piping stress, deflection or bending that may affect the performance of the valve.

1. Prior to installation, check that valve end joints are clean. Check for damage to the valve. Open and close valve to insure proper operation. Close wedge before placing valve in trench or line.

2. Handle valve carefully. Do not drop into position. Do not sling through the port opening.

3. Prepare pipe ends according to manufacturer's instructions. Install valve per proper methods according to end joint type. All piping should be properly supported to avoid line stress on the valve. Do not use the valve as a jack to force a pipeline into position.

4. A valve box or vault should be provided for each valve used in buried service application. These should be installed such that no load is transferred to the valve.

 Before pressurization of the pipeline and valve, all PAGE 2 pressure containing bolting (cover, follower plate, end connection) should be inspected for adequate tightness (usually 90 ft. lbs.). (CONT'D)

6. Buried valves should be pressurized before backfilling.

7. With valve in open position, the entire system should be thoroughly flushed to clean the system. Debris in the valve could prevent valve from closing or possibly damage the resilient material on the wedge.

8. Upon completion of the installation, gate valve location, size, type, date of installation, number of turns to open, direction of opening, and any other special information should be entered on permanent records.

OPERATION

The operation of a RSGV is not like that of a double disc gate valve. In normal circumstances less operating torque is required as the resilient wedge valve just closes, or on opening. Valve operators should adhere to the "Turns to Fully Open RSGV" listed in the table below.

TURNS TO FULLY OPEN RSGV											
MOD	MODEL KS-FW (C509) AND KS-RW (C515)										
SIZE	WITHOUT GEARING	WITH SPUR GEAR	WITH BEVEL GEAR								
2	6.5	N/A	N/A								
2.5	8	N/A	N/A								
3	10	N/A	N/A								
4	13.5	N/A	N/A								
6	19.5	N/A	N/A								
8	25.5	N/A	N/A								
10	31.5	N/A	N/A								
12	37.75	N/A	N/A								
14	52	104	104								
16	52	104	104								
18	64	192	192								
20	64	192	192								
24	76	228	228								
30	98	588	588								
36	114	684	684								
42	100	800	800								
48	100	800	800								
54	100	800	800								

STEM SEAL PROCEDURES

NON-RISING STEM (NRS) VALVES

Before beginning, contact McWane Plant & Industrial or an authorized distributor to obtain: 1. Stem sealing O-rings - (2) req'd 2. One stuffing box gasket / O-ring - (1) req'd

NRS STEM SEAL REPLACEMENT PROCEDURE

 Operate the valve to its full position (apply approx.
50 ft-lbs. torque for valves 3" and smaller, 100 ft-lbs. for valves 4" and larger)

2. Remove the nuts retaining the stuffing box

3. Separate the stuffing box and the cover (The seal between the cover and the stuffing box may require the use of a small pry bar or a soft faced hammer).

4. Remove and replace the O-rings. Wipe all grit and dirt from the bore of the stuffing box and stem. Lubricate the bore of the stuffing box, the stem, and the stem seal O-rings before installing the stem seal O-rings. Two O-rings on the shank of the stem and One O-ring/gasket seal on the bottom of the stuffing box. It may be desirable to use a small amount of a cyanoacrylate adhesive to retain the O-ring during reinstallation. (I.e. Permabond 910, Loctite 404, etc.)

5. Replace the stuffing box. Tighten all bolts uniformly and carefully so that the stuffing box is flat and snug against the cover and the gap between the cover and stuffing box does not exceed 0.015" and uniform (normally there should be no gap). Check the stem for binding but operating the valve.

OUTSIDE SCREW & YOKE (OS&Y)

Before attempting to repack the valve, first attempt to stop the leakage by adjusting (tightening) the brass nuts on the packing gland. Tighten both nuts snugly and uniformly to about 60 ft-lb. The switch groove should be above the packing when brass nuts are tightened. Verify that the switch groove on the stem has smooth corners. Sharp corners exist on some older valves. File as necessary. Operate the valve a time or two to determine if the leakage has stopped. Before beginning repacking, contact McWane Plant & Industrial or an authorized distributor to obtain packing (packing supplied by McWane Plant & Industrial may come in one continuous coil or in segments).

OS&Y PACKING PROCEDURE

 Operate the valve to its fully open position (apply approx. 50 ft-lbs. torque for valves 3" and smaller, 100 ft-lbs. for valves 4" and larger)

2. Verify that the switch groove on the stem has smooth corners. Sharp corners exist on some older valves. File as necessary.

3. Remove the nuts [Item R8] retaining the packing gland.

4. Lift the packing gland. If necessary, lever the packing gland with a crowbar or similar tool.

5. Remove and replace the packing - (if the packing is in multiple or individual rings, be sure to stagger the adjoining ends from one layer to the next). Although not mandatory, it is recommended to use two threaded rods the same diameter as the packing gland bolts and about 6" long to set the packing. Remove the packing gland bolts and replace them with threaded rods through the packing gland and place nuts on the free ends of the threaded rods. Tighten the nuts with a deep well socket until all leakage stops. Exchange the threaded rods for the actual packing gland bolts/nuts (one side and then the other).

6. Reinstall the packing gland bolts and nuts, tightening the nuts uniformly, one side then the other so that the packing gland pulls down evenly. Tighten the nuts until all leakage past the packing stops. Operate the valve through several complete open/close cycles to check for stem binding and to be certain that there is no leakage.

OS&Y PACKING GLAND REPLACEMENT PROCEDURE

1. Remove the packing gland fasteners.

2. Remove the cover fasteners.

3. Rotate the hand wheel in "valve closing direction". This action will allow the entire cover assembly

to travel upward until the threads of the yoke nut completely disengage the threads on the stem.

4. Carefully, lift the cover assembly [cover assembly includes Handwheel Hold Down Nut, Handwheel, Upper Thrust Washer (sizes 3"thru 12"), Lower Thrust Washer, Yoke Nut, Packing Bolts & Nuts, Packing Gland, Packing] up and completely off stem [item R14].

5. Remove the old packing and discard the old packing gland.

6. Position the new packing gland into the packing well of the cover. The packing gland is not meant to be secured at this point.

7. Carefully, reposition the cover assembly over the stem until the end of the stem contacts the starting threads of the yoke nut.

8. Rotate the hand wheel in "valve opening direction". This action will allow the entire cover assembly to travel downward until the cover assembly rests on the top of the body flange. Make sure that the cover O-ring is not damaged and is in position.

9. Bolt the cover to the body, using an alternating tightening pattern, assuring that the cover is down flush to the body (the maximum gap should not exceed 0.015" and should be uniform (normally there should be no gap). See last page for bolt torque recommendations.

10. Refer to the OS&Y Packing Procedure

RESILIENT WEDGE REPLACEMENT

1. It is necessary to take the valve fully out of service to replace the wedge, but it is not necessary to remove the valve from the line.

2. It is very unusual to have to replace a wedge. Discs normally can be expected to last for many years and thousands of cycles. Before replacing a wedge, first check to see if the operation personnel are closing the valve tightly. If the valve is closed tightly, open the valve about five turns and attempt to cause the maximum flow through the valve to flush any debris from the seating area. If it is necessary to replace a wedge suspect that there is some systematic problem causing the wedge failure such as stones in the line.

3. Before attempting to replace the disc, contact McWane Plant & Industrial or an authorized distributor to obtain:

- A. Cover O-Ring
- **B**. Wedge

WEDGE REPLACEMENT PROCEDURE

1. Partially open the valve.

2. Remove the cap (bonnet) bolts and nuts.

3. Lift the cap, stem, stuffing box, disc assembly from the body.

4. Remove and replace the wedge.

5. Replace the cap sealing O-ring (not always necessary) – Retain the O-ring with lubricating grease (Clarion Food Machinery Grease, No. 2). Lubricate stem with same grease.

6. Replace the cap, stem, stuffing box, disc assembly – taking care to start the disc into the guides cast into the body.

7. Place the bolts through the holes in the body and cap – taking care to line the bolt holes up.

8. Snug the cap bolts finger tight and then tighten them. First tighten two bolts diagonally opposite with wrist torque. Then go to another bolt opposite the first two and tighten. Then work around the bolt pattern tightening the bolts.

9. Operate the valve fully open to fully close before backfilling.

TROUBLESHOOTING

PROBLEM	CAUSE	SOLUTION
Joint Leakage	Bolt tension relaxing Foreign material caught in seat	Tighten bolts Operate valve to flush out debris
Seat Leakage	Seat is dirty/corroded	Flush or disassemble & clean
	Seat is damaged Bolts loose	Inspect- repair or replace. Tighten bolts
Leak Past Stem	0-rings worn/damaged (NRS)	Inspect/Replace
	Packaging worn/ damaged (OS&Y)	Inspect/Replace

PARTS & SERVICE

Parts and service are available from your local representative or the factory. For availability and pricing of spare parts please contact the MPI sales team:

McWane Plant & Industrial

www.mcwanepi.com Phone: 866-924-8674 Email: sales@mcwanepi.com



OS&Y RSGV WITH FLANGED ENDS, SIZE 2" - 24"





		PARTS LIST						
SIZE	DESCRIPTION	MATERIAL						
1	Held Deurs Nut	Bronze ASTM B584 C87850 / C57610 (2"-12")						
1	Hold Down Nut	Bronze ASTM B584 C83600 (14"-24")						
2	Yoko Nut	Bronze ASTM B584 C86700 (2"-12")						
~	TOKE NUL	Bronze ASTM B584 C83600 (14"-24")						
3	Handwheel	Ductile Iron ASTM A536 70-50-05 (2"-12")						
	Hundwice	Gray Iron ASTM A126 Class B (14"-24")						
4	Hex Cap Screw	ZN A307 Grade B / ASTM F593 S30400 / S31600						
5	Adapter (14"-24")	Gray Iron ASTM A126 Class B						
6	Yoke	Ductile Iron ASTM A536 70-50-05 (2"-12")						
-		Gray Iron ASTM A126 Class B (14"-24")						
7	Stud (14"-24")	ASTM F593 S30400 / S31600						
8	Hex Nut	ZN A307 Grade B / ASTM F593 S30400 / S31600						
9	Follower Plate (14"-16")	Gray Iron ASTM A126 Class B						
10	Packing Gland	Ductile Iron ASTM A536 70-50-05 (2"-12")						
	-	Bronze ASTM B584 C83600 (14"-24")						
11	Hex Nut	ZN A307 Grade B / ASTM F593 S30400 / S31600						
12	Hex Cap Screw	GR 2 ZN SAE J429 / 304SS ASTM 18-8SS						
13	Hex Nut	ZN A307 Grade B / ASTM F593 S30400 / S31600						
14	Bushing (14-24")	ZN A307 Grade B / ASTM F593 S30400 / S31600						
15	Voko O-Ring	Buna-N ASTM D2000 (2"-12")						
15	Toke o Thing	EPDM (14"-24")						
		304SS ASTM A276 S30400 / 316SS ASTM A276						
		S31600 / ECU Brass ASTM B371 C69300 / Silicon Bronnze "A" (Everdur) ASTM B98 C65500 (2"-12")						
16	Stem	304SS ASTM A276 S30400 / 316SS ASTM A276						
		S31600 / Silicon Bronnze "A" (Everdur) ASTM B98						
		C65500 (14"-24")						
17	Hex Cap Screw	ZN A307 Grade B / ASTM F593 S30400 / S31600						
18	Hex Nut	ZN A307 Grade B / ASTM F593 S30400 / S31600						
19	Flat Washer	ZN A307 Grade B / ASTM F593 S30400 / S31600						
20	Cover	Ductile Iron ASTM A536 70-50-05 (2"-12")						
20	00101	Ductile Iron ASTM A536 65-45-12 (14"-24")						
21	Cover O-Bing	Buna-N ASTM D2000 (2"-12")						
21	oover o ning	EPDM (14"-24")						
22	Stem 0-Ring	Buna-N ASTM D2000 (2"-12")						
~~~	otem o-ming	EPDM (14"-24")						
		Bronze ASTM B584 CDA 844 (2"-12")						
23	Stem Nut	Bronze ASTM B584 C87610 / Bronze ASTM B584						
20	otom nat	C87850 / Bronze ASTM B763 C99500 (NDZ) (14"-20")						
		Bronze ASTM B584 C83600 (24")						
24	Wedge	Ductile Iron ASTM A584 70-50-05 & EPDM (2"-12")						
		Ductile Iron ASTM A536 65-45-12 & EPDM (14"-24")						
25	Body-Flanged Type	Ductile Iron ASTM A536 65-45-12 (2"-24")						
26	Scraper (24")	Bronze ASTM B584 C83600						
27	Roller (24")	Bronze ASTM B584 C83600						
28	Pin (24")	Stainless Steel AISI 303						
29	Square Key (18"-24")	GR 2 ZN ZAE J429						
30	Wedge Cap (18"-20")	Delrin						
31	Track (24")	Stainless Steel AISI 316						
32	Pipe Plug (14"-24")	18-8SS						
33	Packing	Braided, Lubricated (Non-Asbestos)						

	DIMENSIONS												
SIZE	Α	В	С	D	E	F	G	н	J	к	No, Turns to Open	Weight (Ibs.)	
2	7″	5/8″	6″	2″	7-1/4″	6″	13-3/32″	15-7/8″	5/8″ x 4	4-3/4″	6-1/2	42.10	
2-1/2	7-1/2″	11/16″	7″	2-1/2″	7-1/4″	7″	13-7/8″	16-3/8″	5/8″ x 4	5-1/2″	8	52.00	
3	8″	3/4″	7-1/2″	3″	10″	7-1/2″	15-5/8″	18-7/8″	5/8″ x 4	6″	10	67.14	
4	9″	15/16″	9″	4-1/4″	10″	9″	18-1/4″	22-3/4″	5/8″ x 4	7-1/2″	13-1/2	91.85	
6	10-1/2″	1″	11″	6-1/4″	12″	11-3/8″	23-3/4″	30-1/8″	3/4″ x 8	9-1/2″	19-1/2	140.67	
8	11-1/2″	1-1/8″	13-1/2″	8-1/4″	14″	13-1/2″	29-1/4″	37-3/4″	3/4″ x 8	11-3/4″	25-1/2	212.60	
10	13″	1-3/16″	16″	10-1/4″	18″	16″	35-3/8″	45-3/4″	7/8″ x 12	14-1/4″	31-1/2	368.48	
12	14″	1-1/4″	19″	12-1/4″	18″	19″	40-5/8″	53-1/8″	7/8″ x 12	17″	37-3/4	479.41	
14	15″	1-3/8″	21-1/16″	14-1/4″	22″	26-11/16"	59-3/4″	74-3/4″	1″ x 12	18-3/4″	52	670.00	
16	16″	1-7/16″	23-1/2″	16-1/4″	22″	26-11/16"	59-3/4″	74-3/4″	1″ x 16	21-1/4″	52	735.00	
18	17″	1-9/16"	25″	18-1/4″	24″	32-1/4″	71-1/4″	92-9/16″	1-1/4" x 16	22-3/4″	64	1100	
20	18″	1-11/16″	27-1/2″	20-1/4″	24″	32-1/4″	67-3/8″	94-3/8″	1-1/4″ x 20	25″	64	1325	
24	20″	1-7/8″	32″	24-1/4″	32″	38″	81-3/8″	110-5/8″	1-3/8″ x 20	29-1/2″	88	1900	



#### NRS RSGV WITH MECHANICAL JOINTS, WITH HAND WHEEL SIZE 2" - 24"



	PARTS LIST										
SIZE	DESCRIPTION	MATERIAL									
1	Hold Down Nut	Bronze ASTM B584 C87850 / C57610 (2"-12")									
		Bronze ASTM B584 C83600 (14"-24")									
2	Yoke Nut	Bronze ASTM B584 C86700 (2"-12")									
	Toke Wat	Bronze ASTM B584 C83600 (14"-24")									
3	Handwheel	Ductile Iron ASTM A536 70-50-05 (2"-12")									
		Gray Iron ASTM A126 Class B (14"-24")									
4	Hex Cap Screw	ZN A307 Grade B / ASTM F593 S30400 / S31600									
5	Adapter (14"-24")	Gray Iron ASTM A126 Class B									
6	Yoke	Ductile Iron ASTM A536 70-50-05 (2"-12")									
		Gray Iron ASTM A126 Class B (14"-24")									
7	Stud (14"-24")	ASTM F593 S30400 / S31600									
8	Hex Nut	ZN A307 Grade B / ASTM F593 S30400 / S31600									
9	Follower Plate (14"-16")	Gray Iron ASTM A126 Class B									
10	Packing Gland	Ductile Iron ASTM A536 70-50-05 (2"-12")									
	-	Bronze ASTM B584 C83600 (14"-24")									
11	Hex Nut	ZN A307 Grade B / ASTM F593 S30400 / S31600									
12	Hex Cap Screw	GR 2 ZN SAE J429 / 304SS ASTM 18-8SS									
13	Hex Nut	ZN A307 Grade B / ASTM F593 S30400 / S31600									
14	Bushing (14-24")	ZN A307 Grade B / ASTM F593 S30400 / S31600									
15	Yoke O-Bing	Buna-N ASTM D2000 (2"-12")									
		EPDM (14"-24")									
16	Stem	304SS ASTM A276 S30400 / 316SS ASTM A276 S31600 / ECD Brass ASTM B371 C69300 / Silicon Bronnze "A" (Everdur) ASTM B98 C65500 (2"-12")									
		30455 ASTM A276 330400 / 31655 ASTM A276 S31600 / Silicon Bronnze "A" (Everdur) ASTM B98 C65500 (14"-24")									
17	Hex Cap Screw	ZN A307 Grade B / ASTM F593 S30400 / S31600									
18	Hex Nut	ZN A307 Grade B / ASTM F593 S30400 / S31600									
19	Flat Washer	ZN A307 Grade B / ASTM F593 S30400 / S31600									
20	Cover	Ductile Iron ASTM A536 70-50-05 (2"-12")									
20	Cover	Ductile Iron ASTM A536 65-45-12 (14"-24")									
21	Course O. Ping	Buna-N ASTM D2000 (2"-12")									
21	Cover O-hilly	EPDM (14"-24")									
22	Stom O Bing	Buna-N ASTM D2000 (2"-12")									
22	Stelli U-niliy	EPDM (14"-24")									
		Bronze ASTM B584 CDA 844 (2"-12")									
23	Stem Nut	Bronze ASTM B584 C87610 / Bronze ASTM B584 C87850 / Bronze ASTM B763 C99500 (NDZ) (14"-20")									
		Bronze ASTM B584 C83600 (24")									
24	Wedge	Ductile Iron ASTM A584 70-50-05 & EPDM (2"-12")									
27	weage	Ductile Iron ASTM A536 65-45-12 & EPDM (14"-24")									
25	Body-Flanged Type	Ductile Iron ASTM A536 65-45-12 (2"-24")									
26	Scraper (24")	Bronze ASTM B584 C83600									
27	Roller (24")	Bronze ASTM B584 C83600									
28	Pin (24″)	Stainless Steel AISI 303									
29	Square Key (18"-24")	GR 2 ZN ZAE J429									
30	Wedge Cap (18"-20")	Delrin									
31	Track (24")	Stainless Steel AISI 316									
32	Pipe Plug (14"-24")	18-8SS									
33	Packing	Braided, Lubricated (Non-Asbestos)									

6

7

8

9

12

______ [13]

32)

17) 18)

	DIMENSIONS													
SIZE	Α	В	С	D	E	F	н	J	к	No. Turns to Open	Weight (lbs.)			
2	8-1/4″	2-1/2″	4-1/2″	2″	10-7/8″	6″	14-7/16″	4-3/4″	5/8″ x 2	6-1/2	37.14			
3	8-1/2″	2-1/2″	7-3/4″	3″	12-3/8″	7-1/2″	17″	6-1/8″	5/8″ x 4	10	58.00			
4	9-1/2″	2-1/2″	9-1/8″	4-1/4″	14-3/4″	9″	19-3/4″	7-1/2″	3/4″ x 4	13	69.50			
6	10-1/2″	2-1/2″	11-1/8″	6-1/4″	19″	11-3/8″	24-5/16"	9-5/8″	3/4″ x 6	19	110.00			
8	13-1/8″	2-1/2″	13-1/8″	8-1/4″	22-1/2″	13-1/2″	29-11/16″	11-3/4″	3/4″ x 6	25	164.00			
10	15-1/2″	2-1/2″	15-1/2"	10-1/4″	26-1/2"	16″	34-1/2″	14″	3/4″ x 8	31	287.00			
12	16″	2-5/8″	18″	12-1/4″	30″	19″	39″	16″	3/4″ x 8	37	362.00			
14	17″	3-1/2″	20-1/4″	14-1/4″	38-3/4"	26-11/16″	48-1/2″	18-3/4″	3/4" x 10	52	650.00			
16	17″	3-1/2″	22-1/2″	16-1/4″	37-3/4″	26-11/16"	48-5/8″	21″	3/4" x 12	52	720.00			
18	18-3/4″	3-1/2″	24-3/4″	18-1/4″	57-1/16″	32-1/4″	68-13/16″	23-1/4″	7/8″ x 12	64	1250.00			
20	18″	3-1/2″	27″	20-1/4″	56-1/4″	32-1/4″	69-3/8″	25″-1/2	7/8″ x 14	64	1325.00			
24	20″	3-1/2″	32″	24-1/4″	60-1/16″	38″	76-1/16″	29-1/2″	3/4″ x 16	88	1700.00			



# NRS RSGV WITH FLANGED ENDS SIZE 2"-24"

		PARTS LIST					
SIZE	Α	В					
1	Bolt	GR 2 ZN SAE J429					
2	Washer	GR 2 ZN SAE J429					
3	OP Nut	Grey Iron ASTM A126 Class B					
4	Adaptor Plate (18-24")	Ductile Iron ASTM A536 70-50-05					
5	Hex Head Bolt	GR 2 ZN SAE J429 / ASTM F593 S30400/S31600					
6	Cover	Ductile Iron ASTM A536 70-50-05					
7	Body	Ductile Iron ASTM A536 70-50-05					
8	Hex Head Bolt	GR 2 ZN SAE J429 / ASTM F593 S30400/S31600					
9	Hex Nut	GR 2 ZN SAE J429 / ASTM F593 S30400/S31600					
10	Wedge Cover (18"-20")	Delrin					
11	Extension (18"-24")	Ductile Iron ASTM A536 70-50-05					
12	Stuffing Box (2"-16")	Ductile Iron ASTM A536 70-50-05					
13	Thrust Washer	Delrin					
14	Pipe Plug (14"-24")	18-8SS					
15	Track (24")	AL Bronze ASTM B148 C95400					
16	Roller (24")	Copper Alloy ASTM B584 C95400					
17	Pin (24")	in (24") 316 Stainless Steel					
18	Scraper (24")	Copper Alloy ASTM B584 C95400					
19	Square Key (18"-24")	GR 2 ZN SAE J429					
20	0-Ring	EPDM					
21	Stor	Manganese Bronze ASTM B584 C86700 / 304SS ASTM A276 S30400 / 316SS ASTM A276 S31600 / NDZ B763 C99500 (2"-12")					
21	Stem	Manganese Bronze ASTM B584 C86200 / 304SS ASTM A276 S30400 / 316SS ASTM A276 S31600 / NDZ B763 C99500 (14"-24")					
22	0-Ring	EPDM					
22	Otom Nut	Manganese Bronze ASTM B584 C86700 (2"-12")					
23	Stem Nut	Copper Alloy ASTM B584 C87850 (14"-24")					
24	Wedge	Ductile Iron ASTM A536 70-50-05 / EPDM Rubber					
25	Ind. Post Plate Hex Bolts	ASTM F593 S30400					
26	Ind. Post Plate Hex Nuts	ASTM F594 S30400					
27	Stem O-Ring	m O-Ring EPDM					
28	Ind. Post Plate O-Ring	EPDM					





	DIMENSIONS													
SIZE	A	В	C	D	E	F	н	J	к	No. Turns to Open	Weight (lbs.)			
2	7″	5/8″	6″	2″	11-7/16″	6″	14-7/16″	4-3/4″	5/8″ x 4	6-1/2	40.85			
2-1/2	7-1/2″	11/16″	7″	2-1/2″	12-1/16″	7″	15-9/16″	5-1/2″	5/8″ x 4	8	50.53			
3	8″	3/4″	7-1/2″	3″	12-3/8″	7-1/2″	16-15/16″	6″	5/8″ x 4	10	79.29			
4	9″	15/16″	9″	4-1/4″	14-3/4″	9″	20-1/4″	7-1/2″	5/8″ x 4	13	101.75			
6	10-1/2″	1″	11″	6-1/4″	19″	11-3/8″	24-1/8″	9-1/2″	3/4″ x 8	19	139.04			
8	11-1/2″	1-1/8″	13-1/2″	8-1/4″	22-1/2″	13-1/2″	29-1/2″	11-3/4″	3/4″ x 8	25	208.05			
10	13″	1-3/16″	16″	10-1/4″	26-1/2″	16″	34-1/2″	14-1/4″	7/8″ x 12	31	339.52			
12	14″	1-1/4″	19″	12-1/4″	30″	19″	39-1/2″	17″	7/8″ x 12	37	406.78			
14	15″	1-3/8″	21-1/16"	14-1/4″	38-5/16″	26-11/16"	49″	18-3/4″	1″ x 12	52	675.00			
16	16″	1-7/16″	23-1/2″	16-1/4"	37-5/16″	26-11/16"	49-1/8″	21-1/4″	1″ x 16	52	720.00			
18	17″	1-9/16″	25″	18-1/4″	56-1/16″	32-1/4″	68-9/16″	22-3/4″	1-1/4" x 16	64	1100.00			
20	18″	1-11/16″	27-1/2″	20-1/4″	56-1/4″	32-1/4″	70″	25″	1-1/4" x 20	64	1325.00			
24	20″	1-7/8″	32″	24-1/4″	60-1/8″	38″	76-1/8″	29-1/2″	1-3/8″ x 20	88	1732.00			



#### NRS RSGV WITH MECHANICAL JOINTS AND SPUR GEARING SIZE 14"-24"









	DIMENSIONS													
SIZE	ZE A B		C D		E	F	G	н						
14	8	26-11/16	52-1/8	62-1/2	20-1/4	8-1/2	17	3/4" x 10						
16	8	26-11/16	51-1/8	62-1/2	22-1/2	8-1/2	17	3/4″ x 12						
18	12	32-1/4	58	70-1/2	24-3/4	9	18	7/8″ x 12						
20	12	32-1/4	57	70-1/2	27	9	18	7/8″ x 14						
24	12	38	62 <b>-</b> 5/8	78-1/4	31-1/4	10-1/2	21	3/4″ x 16						
								•						

30" & larger sizes require gearing.

24" are now furnished with rollers, tracks, and scrapers.

		PARTS LIST			PARTS	S LIST			F	ARTS LIST	
No.	PART	MATERIAL	ASTM DESIGNATION	No.	PART	MATERIAL	ASTM DESIGNATION	No.	PART	MATERIAL	ASTM DESIGNATION
1	Body	Ductile Iron	ASTM A536 GR 65-45-12	11	Hex Nut	Stainless Steel	ASTM F593-304	20	Hex Bolt	Stainless Steel	ASTM F593-304
2	Cover	Ductile Iron	ASTM A536 GR 65-45-12	12	Extension	Ductile Iron	ASTM A536 65-45-12	21	Hex Nut	Stainless Steel	ASTM F593-304
3	Wedge	Ductile Iron / Rubber EPDM	ASTM A536 GR 65-45-12 / EPDM	13	0-ring	Rubber	NBR	22	Key	Steel	
4	Wedge Cap (18"-24")	Delrin	Delrin	14	Hex Head Bolt	Stainless Steel	ASTM F593-304	23	OP Nut	Ductile Iron	ASTM A536 65-45-12
5	0-ring	Rubber	NBR	15	Actuator - 3:1 (18"-24") 2:1 (14"-16")			24	Pipe Plug	Steel	Steel
6	Stem	Bronze	ASTM B584 C86700	16	Adapter Plate	Ductile Iron	ASTM A536 GR 65-45-12	25	Drive Sleeve	Steel	AISI 1023
7	Stem Nut	Bronze	ASTM B584 C86700	17	Actuator Gasket	Rubber	NBR	26	Cover Bushing	Bronze	ASTM B584 C86700
9	0-ring	Rubber	NBR	18	Socket Head Bolt	Alloy Steel	Alloy Steel	27	Extension Bushing	Bronze	ASTM B584 C86700
10	Hex Head Bolt	Stainless Steel	ASTM F593-304	19	0-ring	Rubber	NBR	28	Thrust Bearing (18"-24")	Delrin	Delrin



NRS RSGV WITH MECHANICAL JOINTS AND BEVEL GEARING SIZE 14"-24"









	DIMENSIONS												
SIZE	Α	В	C	D	E	F	G	н	J				
14	9-1/8	26-11/16	48-5/8	59	20-1/4	8-1/2	17	3/4" x 10	46-5/8				
16	9-1/8	26-11/16	47-5/8	59	22-1/2	8-1/2	17	3/4″ x 12	45-5/8				
18	10-1/8	32-1/4	55-3/4	68-1/4	24-3/4	9-5/32	18	7/8″ x 12	53-3/4				
20	10-1/8	32-1/4	54-3/4	68-1/4	27	9-5/32	18	7/8″ x 14	52-3/4				
24	10-1/8	38	59-7/8	75-1/8	31-1/2	9-1/2	19	3/4″ x 16	57-3/8				
30″ &	30" & larger sizes require gearing.												
24° ar	e turnishe	a with roller	s, tracks,	and scrap	oers.								

		PARTS LIST			PARTS	S LIST		PARTS LIST				
No.	PART	MATERIAL	ASTM DESIGNATION	No.	PART	MATERIAL	ASTM DESIGNATION	No.	PART	MATERIAL	ASTM DESIGNATION	
1	Body	Ductile Iron	ASTM A536 GR 65-45-12	11	Hex Nut	Stainless Steel	ASTM F593-304	20	Hex Bolt	Stainless Steel	ASTM F593-304	
2	Cover	Ductile Iron	ASTM A536 GR 65-45-12	12	Extension	Ductile Iron	ASTM A536 65-45-12	21	Hex Nut	Stainless Steel	ASTM F593-304	
3	Wedge	Ductile Iron / Rubber EPDM	ASTM A536 GR 65-45-12 / EPDM	13	0-ring	Rubber	NBR	22	Кеу	Steel		
4	Wedge Cap (18"-24")	Delrin	Delrin	14	Hex Head Bolt	Stainless Steel	ASTM F593-304	23	OP Nut	Ductile Iron	ASTM A536 65-45-12	
5	0-ring	Rubber	NBR	15	Actuator - 3:1 (18"-24") 2:1 (14"-16")			24	Pipe Plug	Steel	Steel	
6	Stem	Bronze	ASTM B584 C86700	16	Adapter Plate	Ductile Iron	ASTM A536 GR 65-45-12	25	Drive Sleeve	Steel	AISI 1023	
7	Stem Nut	Bronze	ASTM B584 C86700	17	Actuator Gasket	Rubber	NBR	26	Cover Bushing	Bronze	ASTM B584 C86700	
9	0-ring	Rubber	NBR	18	Socket Head Bolt	Alloy Steel	Alloy Steel	27	Extension Bushing	Bronze	ASTM B584 C86700	
10	Hex Head Bolt	Stainless Steel	ASTM F593-304	19	0-ring	Rubber	NBR	28	Thrust Bearing (18"-24")	Delrin	Delrin	



NRS RSGV WITH FLANGED ENDS AND SPUR GEARING SIZE 14"-24"





	DIMENSIONS												
SIZE	Α	В	C	D	E	F	G	н					
14     8     26-11/16     52-1/8     63     21     7-1/2     15     1" x 12													
16	16 8 26-11/16 51-1/8 63 23-1/2 8 16 1" x 16												
18	12	32-1/4	58	70-1/2	25	8-1/2	17	1-1/8″ x 16					
20	12	32-1/4	57	70-1/2	27-1/2	9	18	1-1/8″ x 20					
24	24 12 38 62-5/8 78-5/8 32 10 20 1-3/8" x 20												
30″ &	30" & larger sizes require gearing.												

24" are now furnished with rollers, tracks, and scrapers.

-6





		PARTS LIST		PARTS LIST					PARTS LIST				
No.	PART	MATERIAL	ASTM DESIGNATION	No.	PART	MATERIAL	ASTM DESIGNATION	No.	PART	MATERIAL	ASTM DESIGNATION		
1	Body	Ductile Iron	ASTM A536 GR 65-45-12	11	Hex Nut	Stainless Steel	ASTM F593-304	20	Hex Bolt	Stainless Steel	ASTM F593-304		
2	Cover	Ductile Iron	ASTM A536 GR 65-45-12	12	Extension	Ductile Iron	ASTM A536 65-45-12	21	Hex Nut	Stainless Steel	ASTM F593-304		
3	Wedge	Ductile Iron / Rubber EPDM	ASTM A536 GR 65-45-12 / EPDM	13	0-ring	Rubber	NBR	22	Key	Steel			
4	Wedge Cap (18"-24")	Delrin	Delrin	14	Hex Head Bolt	Stainless Steel	ASTM F593-304	23	OP Nut	Ductile Iron	ASTM A536 65-45-12		
5	0-ring	Rubber	NBR	15	Actuator - 3:1 (18"-24") 2:1 (14"-16")			24	Pipe Plug	Steel	Steel		
6	Stem	Bronze	ASTM B584 C86700	16	Adapter Plate	Ductile Iron	ASTM A536 GR 65-45-12	25	Drive Sleeve	Steel	AISI 1023		
7	Stem Nut	Bronze	ASTM B584 C86700	17	Actuator Gasket	Rubber	NBR	26	Cover Bushing	Bronze	ASTM B584 C86700		
9	0-ring	Rubber	NBR	18	Socket Head Bolt	Alloy Steel	Alloy Steel	27	Extension Bushing	Bronze	ASTM B584 C86700		
10	Hex Head Bolt	Stainless Steel	ASTM F593-304	19	0-ring	Rubber	NBR	28	Thrust Bearing (18"-24")	Delrin	Delrin		



#### NRS RSGV WITH FLANGED ENDS AND BEVEL GEARING 14"-24"









∟ H- No. & Size of Bolts Drilling per ANSI B16.1 Class 125

	DIMENSIONS												
SIZE	Α	В	С	D	E	F	G	н	J				
14	9-1/8	26-11/16	48-5/8	59-1/2	21	7-1/2	15	1″ x 12	46-3/8				
16	9-1/8	26-11/16	47-5/8	59-1/2	23-1/2	8	16	1″ x 16	45-3/8				
18	10-1/8	32-1/4	55-3/4	68-1/4	25	8-1/2	17	1-1/8″ x 16	55-3/4				
20	10-1/8	32-1/4	54-3/4	68-1/4	27-1/2	9	18	1-1/8″ x 20	52-3/4				
24	24 10-1/8 38 60-3/8 76-1/4 32 10 20 1-3/8" x 20 57-7/8												
30″ &	30" & larger sizes require gearing												

24" are furnished with rollers, tracks, and scrapers.

		PARTS LIST			PARTS	S LIST		PARTS LIST				
No.	PART	MATERIAL	ASTM DESIGNATION	No.	PART	MATERIAL	ASTM DESIGNATION	No.	PART	MATERIAL	ASTM DESIGNATION	
1	Body	Ductile Iron	ASTM A536 GR 65-45-12	11	Hex Nut	Stainless Steel	ASTM F593-304	20	Hex Bolt	Stainless Steel	ASTM F593-304	
2	Cover	Ductile Iron	ASTM A536 GR 65-45-12	12	Extension	Ductile Iron	ASTM A536 65-45-12	21	Hex Nut	Stainless Steel	ASTM F593-304	
3	Wedge	Ductile Iron / Rubber EPDM	ASTM A536 GR 65-45-12 / EPDM	13	0-ring	Rubber	NBR	22	Кеу	Steel		
4	Wedge Cap (18"-24")	Delrin	Delrin	14	Hex Head Bolt	Stainless Steel	ASTM F593-304	23	OP Nut	Ductile Iron	ASTM A536 65-45-12	
5	0-ring	Rubber	NBR	15	Actuator - 3:1 (18"-24") 2:1 (14"-16")			24	Pipe Plug	Steel	Steel	
6	Stem	Bronze	ASTM B584 C86700	16	Adapter Plate	Ductile Iron	ASTM A536 GR 65-45-12	25	Drive Sleeve	Steel	AISI 1023	
7	Stem Nut	Bronze	ASTM B584 C86700	17	Actuator Gasket	Rubber	NBR	26	Cover Bushing	Bronze	ASTM B584 C86700	
9	0-ring	Rubber	NBR	18	Socket Head Bolt	Alloy Steel	Alloy Steel	27	Extension Bushing	Bronze	ASTM B584 C86700	
10	Hex Head Bolt	Stainless Steel	ASTM F593-304	19	0-ring	Rubber	NBR	28	Thrust Bearing (18"-24")	Delrin	Delrin	



#### OS&Y RSGV WITH FLANGED ENDS, AND BEVEL GEARING SIZE 14"-24"



	DIMENSIONS												
SIZE	SIZE A B C D E G H J K												
14	15″	1-3/8″	21-1/16″	14-1/4″	59-7/8″	59-3/4″	74-3/4″	1″ X 12	18-3/4″	52			
16	16″	1-7/16″	23-1/2″	16-1/4″	59-7/8″	59-3/4″	74-3/4″	1″ X 16	21-1/4″	52			
18	17″	1-9/16″	25″	18-1/4″	70-1/8″	71-1/4″	92-9/16″	1-1/4" X 16	22-3/4″	64			
20	18″	1-11/16″	27-1/2″	20-1/4″	70-1/8″	67-3/8″	94-3/8″	1-1/4" X 20	25″	64			
24	20″	1-7/8″	32″	24-1/4″	78-7/8″	81-3/8″	110-5/8″	1-3/8″ X 20	29-1/2″	88			

		PARTS LIST			PARTS LIST			PARTS LIST
No.	PART	MATERIAL	No.	PART	MATERIAL	No.	PART	MATERIAL
1	EXEECO IB7	Bronze ASTM B584 C83600	12	Hex Cap Screw	GR 2 ZN SAE J429 / 304SS ASTM 18-8SS	23	Stem Nut	Bronze ASTM B584 C87610 / Bronze ASTM B584 C87850 /
2	Square Key	GR 2 ZN SAE J429	13	Hex Nut	ZN A307 Grade B / ASTM F593 S30400/S31600			Bronze ASTM B763 C99500 (NDZ) (14"-20")
3	OP Nut	Gray Iron ASTM A126 Class B	14	Bushing	ZN A307 Grade B / ASTM F593 S30400/S31600			Bronze ASTM B584 C83600 (24")
4	Output Sleeve	Aluminum Bronze ASTM B505 C95800	15	Yoke O-ring	EPDM	24	Wedge	Ductile Iron ASTM A536 Grade 65-45-12
5	Roll Pin	Stainless Steel	16	Stem	304SS ASTM A276 S30400 / 316SS ASTM A276 S31600 /	25	Body-Flanged Type	Ductile Iron ASTM A536 Grade 65-45-12
6	Yoke	Gray Iron ASTM A126 Class B			Silicon Bronze "A" (Everdur) ASTM B98 C65500	26	Scraper (24")	Bronze ASTM B584 C83600
7	Stud	ASTM F593 S30400/S31600	17	Hex Cap Screw	ZN A307 Grade B / ASTM F593 S30400/S31600	27	Roller (24")	Bronze ASTM B584 C83600
8	Hex Nut	ZN A307 GRADE B / ASTM F593 S30400/S31600	18	Hex Nut	ZN A307 Grade B / ASTM F593 S30400/S31600	28	Pin (24")	Stainless Steel AISI 303
9	Follower Plate	Gray Iron ASTM A126 Class B	19	Pipe Plug	18-8SS	29	Hex Cap Screw	ZN A307 Grade B / ASTM F593 S30400 / S31600
	(14"-16")		20	Cover	Ductile Iron ASTM A536 65-45-12 ASTM B16 Alloy 306	30	Wedge Cap (18"-20")	Delrin
10	Packing Gland	Bronze ASTM B584 C83600	21	Cover O-Ring	EPDM	31	Track (24")	Stainless Steel AISI 316
11	Packing	Braided, Lubricated (Non-Asbestos) Fiber	22	Stem O-Ring	EPDM			



OS&Y RSGV WITH FLANGED ENDS, AND SPUR GEARING SIZE 14"-24"



	DIMENSIONS												
SIZE	A	В	C	D	E	G	н	J	к	to Open	(lbs.)		
14	15″	1-3/8″	21-1/16″	14-1/4″	64-1/2″	59-3/4″	74-3/4″	1″ X 12	18-3/4″	52	670.00		
16	16″	1-7/16″	23-1/2″	16-1/4″	64-1/2″	59-3/4″	74-3/4″	1″ X 16	21-1/4″	52	735.00		
18	17″	1-9/16″	25″	18-1/4″	74-5/8″	71-1/4″	92-9/16″	1-1/4" X 16	22-3/4″	64	1100		
20	18″	1-11/16″	27-1/2″	20-1/4″	74-5/8″	67-3/8″	94-3/8″	1-1/4" X 20	25″	64	1325		
24	20″	1-7/8″	32″	24-1/4″	83-1/2″	81-3/8″	110-5/8″	1-3/8" X 20	29-1/2″	88	1900		

		PARTS LIST			PARTS LIST			PARTS LIST
No.	PART	MATERIAL	No.	PART	MATERIAL	No.	PART	MATERIAL
1	EXEECO IS7	Bronze ASTM B584 C83600	12	Hex Cap Screw	GR 2 ZN SAE J429 / 304SS ASTM 18-8SS	23	Stem Nut	Bronze ASTM B584 C87610 / Bronze ASTM B584 C87850 /
2	Square Key	GR 2 ZN SAE J429	13	Hex Nut	ZN A307 Grade B / ASTM F593 S30400/S31600			Bronze ASTM B763 C99500 (NDZ) (14"-20")
3	OP Nut	Gray Iron ASTM A126 Class B	14	Bushing	ZN A307 Grade B / ASTM F593 S30400/S31600			Bronze ASTM B584 C83600 (24")
4	Output Sleeve	Aluminum Bronze ASTM B505 C95800	15	Yoke O-ring	EPDM	24	Wedge	Ductile Iron ASTM A536 Grade 65-45-12
5	Ro <b>ll</b> Pin	Stainless Steel	16	Stem	304SS ASTM A276 S30400 / 316SS ASTM A276 S31600 /	25	Body-Flanged Type	Ductile Iron ASTM A536 Grade 65-45-12
6	Yoke	Gray Iron ASTM A126 Class B			Silicon Bronze "A" (Everdur) ASTM B98 C65500	26	Scraper (24")	Bronze ASTM B584 C83600
7	Stud	ASTM F593 \$30400/\$31600	17	Hex Cap Screw	ZN A307 Grade B / ASTM F593 S30400/S31600	27	Roller (24")	Bronze ASTM B584 C83600
8	Hex Nut	ZN A307 GRADE B / ASTM F593 S30400/S31600	18	Hex Nut	ZN A307 Grade B / ASTM F593 S30400/S31600	28	Pin (24")	Stainless Steel AISI 303
9	Follower Plate	Gray Iron ASTM A126 Class B	19	Pipe Plug	18-8SS	29	Hex Cap Screw	ZN A307 Grade B / ASTM F593 S30400 / S31600
	(14"-16")		20	Cover	Ductile Iron ASTM A536 65-45-12 ASTM B16 Alloy 306	30	Wedge Cap (18"-20")	Delrin
10	Packing Gland	Bronze ASTM B584 C83600	21	Cover O-Ring	EPDM	31	Track (24")	Stainless Steel AISI 316
11	Packing	Braided, Lubricated (Non-Asbestos) Fiber	22	Stem O-Ring	EPDM			



#### RSGV NRS FLANGED ENDS, WITH BEVEL GEAR SIZE 3"-12"

ITEM	DESCRIPTION	MATERIAL	MATERIAL SPECIFICATION			
001	BODY	GRAY IRON	ASTM A126 CLASS B			
001	BODT	DUCTILE IRON	ASTM A536 65-45-12			
002	COVER	GRAY IRON	ASTM A126 CLASS B			
002	COVER	DUCTILE IRON	ASTM A536 65-45-12			
008			ASTM F593-304 (STANDARD)			
000	GEAR BOETS	STAINLESS STEEL	ASTM F593-316 (OPTIONAL)			
009	2" SQUARE OP NUT	STEEL				
010	HANDWHEEL	STEEL				
012	STUFFING BOX W/ GEAR MOUNT	DUCTILE IRON	ASTM A536 65-45-12			
024	WEDGE	DUCTILE IRON/RUBBER	ASTM A536 65-45-12/EPDM			
038	THRUST WASHER	DELRIN	DELRIN			
049	BEVEL GEAR		IB5 FA14 2:1 RATIO			
071	STEM NUT	BRASS	ASTM B584 C87850			
		BRONZE	ASTM B583 C86700 (STANDARD)			
168	STEM	304 SS	(OPTIONAL)			
		316 SS	(OPTIONAL)			
174	COVER HEX BOLTS		ASTM F593-304 (STANDARD)			
1/4	COVER HEX BOEIS	STAINLESS STEEL	ASTM F593-316 (OPTIONAL)			
175	COVER HEX NUTS		ASTM F594-304 (STANDARD)			
175	COVER HEXINDIS	STAINLESS STEEL	ASTM F594-316 (OPTIONAL)			
176	STUEEING BOX HEX BOI TS		ASTM F593-304 (STANDARD)			
170	STOPPING BOX NEX BOEIS	STAINLESS STELL	ASTM F593-316 (OPTIONAL)			
177			ASTM F594-304 (STANDARD)			
177	STOFFING BOAREANOTS	STAINLESS STEEL	ASTM F594-316 (OPTIONAL)			
179	WASHER	STEEL	STEEL			
320	COVER O-RING	RUBBER	EPDM			
353	STEM O-RING	RUBBER	EPDM			
358	EXTENSION O-RING	RUBBER	EPDM			



SIZE	ØA	В	С	ØD	Е	F	G	ØН	фЈ	J#	К	HANDWHEEL TYPE	ØНW	WEIGHT (LBS.)
3	3.00	4.00	8.00	7.50	7.50	8.56	1.75	6.00	.75	4	.75	F300/30	11.8	118
4	4.00	4.50	9.00	9.00	9.00	10.47	1.75	7.50	.75	8	.94	F300/30	11.8	144
6	6.00	5.25	10.50	11.00	11.38	13.44	2.00	9.50	.88	8	1.00	F400/30	15.7	194
8	8.00	5.75	11.50	13.50	13.50	17.25	2.00	11.75	.88	8	1.13	F500/30	19.7	267
10	10.00	6.50	13.00	16.00	16.00	21.12	2.25	14.25	1.00	12	1.19	F600/30	23.6	398
12	12.00	7.00	14.00	19.00	19.00	24.38	2.25	17.00	1.00	12	1.25	F600/30	23.6	479



#### KS-FW NRS MJ C509 WITH BEVELD GEAR SIZE 3"-12"

ITEM	DESCRIPTION	MATERIAL	MATERIAL SPECIFICATION			
001	BODY - MECHANICAL JOINT	CAST IRON	A126 CLASS B			
002	COVER	CAST IRON	A126 CLASS B			
800	GEAR BOLTS	STAINLESS STEEL	ASTM F593-304			
009	2" SQUARE OP NUT	CAST IRON	A126 CLASS B			
012	STUFFING BOX W/ GEAR MOUNT	CAST IRON	ASTM A536 65-45-12			
024	WEDGE	DUCTILE IRON/RUBBER	ASTM A536 65-45-12/EPDM			
038	THRUST WASHER	DELRIN	DELRIN			
049	ROTORK BEVEL GEAR		IB5 FA14 4:1 RATIO			
071	STEM NUT	BRASS	ASTM B584 C83600			
168	STEM	BRONZE	ASTM B583 C86700			
174	COVER HEX BOLTS	STAINLESS STEEL	ASTM F593-304			
175	COVER HEX NUTS	STAINLESS STEEL	ASTM F593-304			
176	STUFFING BOX HEX BOLTS	STAINLESS STEEL	ASTM F593-304			
177	STUFFING BOX HEX NUTS	STAINLESS STEEL	ASTM F593-304			
179	WASHER	STEEL	STEEL			
320	COVER O-RING	RUBBER	EPDM			
353	STEM O-RING	RUBBER	EPDM			
358	EXTENSION O-RING	RUBBER	EPDM			



SIZE	ØA	В	С	ØD	E	F	G	ØН	ØJ	J#	WEIGHT (LBS.)
3	3.00	2.50	8.50	7.75	7.50	8.56	1.75	6.13	.75	4	90
4	4.25	2.51	9.50	9.13	9.00	10.47	1.75	7.50	.88	4	138
6	6.25	2.51	10.50	11.38	11.38	13.44	2.00	9.63	.88	6	180
8	8.25	2.52	13.13	13.75	13.50	17.25	2.00	11.75	.88	6	256
10	10.25	2.52	15.50	15.75	16.00	21.12	2.25	14.00	.88	8	367
12	12.25	2.66	16.00	18.00	19.00	24.38	2.25	16.25	.88	8	533



### NRS GATE VALVE MECHANICAL JOINT SIZES 2"-24"



PARTS LIST							
SIZE	Α	В					
1	Bolt	GR 2 ZN SAE J429					
2	Washer	GR 2 ZN SAE J429					
3	OP Nut	Grey Iron ASTM A126 Class B					
4	Adaptor Plate (18-24")	Ductile Iron ASTM A536 70-50-05					
5	Hex Head Bolt	GR 2 ZN SAE J429 / ASTM F593 S30400/S31600					
6	Cover	Ductile Iron ASTM A536 70-50-05					
7	Body	Ductile Iron ASTM A536 70-50-05					
8	Hex Head Bolt	GR 2 ZN SAE J429 / ASTM F593 S30400/S31600					
9	Hex Nut	GR 2 ZN SAE J429 / ASTM F593 S30400/S31600					
10	Wedge Cover (18"-20")	Delrin					
11	Extension (18"-24")	Ductile Iron ASTM A536 70-50-05					
12	Stuffing Box (2"-16")	Ductile Iron ASTM A536 70-50-05					
13	Thrust Washer	Delrin					
14	Pipe Plug (14"-24")	18-8SS					
15	Track (24")	AL Bronze ASTM B148 C95400					
16	Roller (24″)	Copper Alloy ASTM B584 C95400					
17	Pin (24")	316 Stainless Steel					
18	Scraper (24")	Copper Alloy ASTM B584 C95400					
19	Square Key (18"-24")	GR 2 ZN SAE J429					
20	O-Ring	EPDM					
21	Store	Manganese Bronze ASTM B584 C86700 / 304SS ASTM A276 S30400 / 316SS ASTM A276 S31600 / NDZ B763 C99500 (2"-12")					
21	Stem	Manganese Bronze ASTM B584 C86200 / 304SS ASTM A276 S30400 / 316SS ASTM A276 S31600 / NDZ B763 C99500 (14"-24")					
22	0-Ring	EPDM					
22	Stom Nut	Manganese Bronze ASTM B584 C86700 (2"-12"					
23	Stem Nut	Copper Alloy ASTM B584 C87850 (14"-24")					
24	Wedge	Ductile Iron ASTM A536 70-50-05 / EPDM Rubber					
25	Ind. Post Plate Hex Bolts	ASTM F593 S30400					
26	Ind. Post Plate Hex Nuts	ASTM F594 S30400					
27	Stem O-Ring	EPDM					
28	Ind. Post Plate O-Ring	EPDM					





DIMENSIONS											
SIZE	A	В	C	D	E	F	н	J	к	No. Turns to Open	
2	8-1/4″	2-1/2″	4-1/2″	2″	10-7/8″	6″	14-7/16″	4-3/4″	5/8″ x 2	6-1/2	
3	8-1/2″	2-1/2″	7-3/4″	3″	12-3/8″	7-1/2″	17″	6-1/8″	5/8″ x 4	10	
4	9-1/2″	2-1/2″	9-1/8″	4-1/4″	14-3/4″	9″	19-3/4″	7 <b>-</b> 1/2″	3/4″ x 4	13	
6	10-1/2″	2-1/2″	11-1/8″	6-1/4″	19″	11-3/8″	24-5/16″	9-5/8″	3/4″ x 6	19	
8	13-1/8″	2-1/2″	13-1/8″	8-1/4″	22-1/2″	13-1/2″	29-11/16″	11-3/4″	3/4″ x 6	25	
10	15-1/2″	2-1/2″	15-1/2″	10-1/4″	26-1/2″	16″	34-1/2″	14″	3/4″ x 8	31	
12	16″	2-5/8″	18″	12-1/4″	30″	19″	39″	16″	3/4″ x 8	37	
14	17″	3-1/2″	20-1/4″	14-1/4″	38-3/4"	26-11/16"	48-1/2″	18-3/4″	3/4" x 10	52	
16	17″	3-1/2″	22-1/2″	16-1/4″	37-3/4″	26-11/16"	48-5/8″	21″	3/4″ x 12	52	
18	18-3/4″	3-1/2″	24-3/4″	18-1/4″	57-1/16″	32-1/4″	68-13/16″	23-1/4″	7/8″ x 12	64	
20	18″	3-1/2″	27″	20-1/4″	56-1/4″	32-1/4″	69-3/8″	25″-1/2	7/8″ x 14	64	
24	20″	3-1/2″	32″	24-1/4″	60-1/16″	38″	76-1/16″	29-1/2″	3/4″ x 16	88	